

COAL INDIA LIMITED									
MARKETING & SALES DIVISION									
COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT									
Region/State	Name of Thermal Power Station	Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Coal Stock (In '000 Tonnes')	In Days	Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock
A	B	C	D	E	F	G	H=(G/F)		
Haryana									
1	INDIRA GANDHI STPP	0.67	21.1	13.19	21.1	137.1	6		
2	MAHATMA GANDHI TPS	0.61	9.1	10.63	10.6	425.3	40		
3	PANIPAT TPS	0.71	10.9	6.68	10.9	75.2	7		
4	RAJIV GANDHI TPS	0.73	8.3	11.64	11.6	255.1	22		
5	YAMUNA NAGAR TPS	0.72	8.7	5.73	8.7	70.4	8		
Punjab									
6	GH TPS (LEH.MOH.)	0.68	9.4	8.28	9.4	87.7	9		
7	GOINDWAL SAHIB TPP	0.71	0.0	5.04	5.0	6.5	1		
8	RAJPURA TPP	0.55	17.8	10.14	17.8	327.7	18		
9	ROPAR TPS	0.68	7.0	7.51	7.5	120.0	16		
10	TALWANDI SABO TPP	0.66	18.9	17.29	18.9	107.1	6		Materialization against the ACQ is more than trigger level
Rajasthan									
11	CHHABRA-I PH-1 TPP	0.50	6.3	3.31	6.3	0.8	0		Materialization against the ACQ is more than trigger level
12	KAWAI TPS	0.60	17.2	10.39	17.2	44.3	3		Materialization against the ACQ is more than trigger level
13	KOTA TPS	0.71	15.5	11.59	15.5	87.0	6		Materialization against the ACQ is more than trigger level
14	SURATGARH TPS	0.49	17.2	9.67	17.2	50.5	3		Materialization against the ACQ is more than trigger level
Uttar Pradesh									
15	ANPARA C TPS	0.64	17.3	10.15	17.3	51.1	3		
16	ANPARA TPS	0.65	40.3	22.69	40.3	269.9	7		
17	BARKHERA TPS	0.80	0.9	0.95	1.0	8.0	8		
18	DADRI (NCTPP)	0.67	24.8	16.20	24.8	83.1	3		
19	HARDUAGANJ TPS	0.74	14.7	12.37	14.7	67.1	5		
20	KHAMBARKHERA TPS	0.80	0.8	0.95	1.0	1.4	1		
21	KUNDARKI TPS	0.76	1.0	0.90	1.0	1.4	1		
22	LALITPUR TPS	0.61	25.5	15.99	25.5	80.5	3		Materialization against the ACQ is more than trigger level
23	MAQSODPUR TPS	0.79	0.8	0.94	0.9	11.2	12		
24	MEJA STPP	0.67	11.3	11.76	11.8	368.8	31		
25	OBRA TPS	0.77	11.7	11.09	11.7	94.7	8		
26	PARICHA TPS	0.71	11.2	10.72	11.2	24.3	2		Materialization against the ACQ is more than trigger level
27	PRAYAGRAJ TPP	0.63	23.9	16.34	23.9	232.3	10		
28	RIHAND STPS	0.64	42.4	25.28	42.4	1197.5	28		
29	ROSA TPP Ph-I	0.66	10.2	10.39	10.4	12.9	1		Materialization against the ACQ is more than trigger level
30	SINGRAULI STPS	0.66	25.8	17.45	25.8	532.1	21		
31	TANDA TPS	0.69	26.4	16.14	26.4	74.8	3		
32	UNCHAHAHAR TPS	0.67	20.8	13.65	20.8	53.6	3		
33	UTRAULA TPS	0.78	0.9	0.93	0.9	0.2	0		
Total of Northern Region								0	
Western									
Chhatisgarh									
34	AKALTARA TPS	0.64	23.4	15.25	23.4	122.4	5		
35	BALCO TPS	0.71	8.3	5.60	8.3	209.1	25		
36	BANDAKHAR TPP	0.71	5.0	2.81	5.0	10.8	2		
37	BARADARHA TPS	0.77	20.5	12.25	20.5	324.1	16		
38	BHILAI TPS	0.76	8.7	5.01	8.7	134.9	15		
39	BINJKOTE TPP	0.75	0.0	5.95	6.0	25.1	4		Materialization against the ACQ is more than trigger level
40	DSPM TPS	0.69	8.9	4.56	8.9	116.0	13		
41	KORBA STPS	0.67	40.0	22.94	40.0	551.7	14		
42	KORBA-WEST TPS	0.78	20.0	13.79	20.0	224.6	11		
43	LARA TPP	0.66	22.9	13.92	22.9	389.5	17		

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

Region/State	Name of Thermal Power Station	Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Coal Stock (In '000 Tonnes')	In Days	Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock
A	B	C	D	E	F	G	H=(G/F)		
44	NAWAPARA TPP	0.79	0.0	6.28	6.3	4.1	1		Materialization against the ACQ is more than trigger level
45	PATHADI TPP	0.65	6.8	5.18	6.8	42.8	6		
46	SIPAT STPS	0.68	29.4	26.62	29.4	573.5	20		
47	TAMNAR TPP	0.84	29.2	26.52	29.2	175.5	6		Materialization against the ACQ is more than trigger level
48	UCHPINDA TPP	0.75	24.9	14.22	24.9	140.5	6		Materialization against the ACQ is more than trigger level
Gujarat									
49	GANDHI NAGAR TPS	0.69	8.8	5.71	8.8	105.0	12		Materialization against the ACQ is more than trigger level
50	SABARMATI (D-F STATIONS)	0.57	4.6	2.74	4.6	33.7	#REF!		
51	UKAI TPS	0.67	15.4	9.85	15.4	59.0	4		Materialization against the ACQ is more than trigger level
52	WANAKBORI TPS	0.67	27.0	20.22	27.0	159.9	6		Materialization against the ACQ is more than trigger level
Madhya Pradesh									
53	AMARKANTAK EXT TPS	0.65	3.2	1.80	3.2	49.2	16		
54	ANUPPUR TPP	0.65	16.6	10.31	16.6	327.0	20		
55	BINA TPS	0.74	5.7	4.88	5.7	21.9	4		
56	GADARWARA TPP	0.66	18.8	13.93	18.8	48.5	3		Materialization against the ACQ is more than trigger level
57	KHARGONE STPP	0.60	7.8	10.45	10.4	190.3	18		Materialization against the ACQ is more than trigger level
58	SANJAY GANDHI TPS	0.82	14.6	14.57	14.6	34.7	2		Non payment of dues
59	SATPURA TPS	0.67	7.6	11.79	11.8	48.9	4		Non Payment of Dues
60	SEIONI TPP	0.64	9.3	5.06	9.3	51.1	5		
61	SHREE SINGAJI TPP	0.71	31.2	23.50	31.2	147.1	5		Non Payment of Dues
62	VINDHYACHAL STPS	0.69	61.3	43.60	61.3	1617.4	26		
Maharashtra									
63	AMRAVATI TPS	0.62	20.2	11.07	20.2	75.3	4		Materialization against the ACQ is more than trigger level
64	BHUSAWAL TPS	0.72	18.3	11.44	18.3	21.0	1		Non payment of dues
65	BUTIBORI TPP	0.67	0.0	5.31	5.3	59.7	11		
66	CHANDRAPUR(MAHARASHTRA) STPS	0.78	40.1	30.17	40.1	300.6	7		Non payment of dues
67	DAHANU TPS	0.62	5.9	4.09	5.9	0.7	0		Materialization against the ACQ is more than trigger level
68	DHARIWAL TPP	0.67	8.3	5.34	8.3	76.1	9		Materialization against the ACQ is more than trigger level
69	GMR WARORA TPS	0.67	8.9	5.29	8.9	42.2	5		Materialization against the ACQ is more than trigger level
70	KHAPARKHEDA TPS	0.89	21.0	15.72	21.0	117.8	6		
71	KORADI TPS	0.76	22.8	22.08	22.8	97.4	4		Non payment of dues
72	MAUDA TPS	0.70	29.5	21.29	29.5	60.1	2		
73	NASIK TPS	0.81	5.9	6.72	6.7	9.6	1		Non payment of dues
74	PARAS TPS	0.74	7.8	4.90	7.8	30.1	4		Non payment of dues
75	PARLI TPS	0.67	8.4	6.65	8.4	43.6	5		Non payment of dues
76	SOLAPUR STPS	0.56	10.5	9.73	10.5	46.2	4		Materialization against the ACQ is more than trigger level
77	TIRORA TPS	0.66	48.0	28.73	48.0	206.9	4		Materialization against the ACQ is more than trigger level
78	WARDHA WARORA TPP	0.66	4.8	4.71	4.8	129.4	27		
Total of Western Region								0	
Southern									
Andhra Pradesh									
79	DAMODARAM SANJEEVAIAH TPS	0.66	10.3	13.85	13.8	110.3	8		Materialization against the ACQ is more than trigger level
80	Dr. N.TATA RAO TPS	0.77	29.9	17.90	29.9	63.5	2		Materialization against the ACQ is more than trigger level
81	PAINAMPURAM TPP	0.59	18.4	10.21	18.4	109.1	6		

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

Region/State	Name of Thermal Power Station	Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Coal Stock (In '000 Tonnes')	In Days	Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock
A	B	C	D	E	F	G	H=(G/F)		
	82 RAYALASEEMA TPS	0.76	19.6	16.60	19.6	51.9	3		Materialization against the ACQ is more than trigger level
	83 SIMHADRI	0.78	30.8	20.54	30.8	192.4	6		
	84 SGPL TPP	0.53	17.2	9.26	17.2	28.6	2		Materialization against the ACQ is more than trigger level
	85 VIZAG TPP	0.67	7.2	9.20	9.2	51.1	6		
Karnataka									
	86 BELLARY TPS	0.63	13.5	14.23	14.2	72.0	5		Materialization against the ACQ is more than trigger level
	87 KUDGI STPP	0.63	20.5	19.90	20.5	60.7	3		Materialization against the ACQ is more than trigger level
	88 RAICHUR TPS	0.66	15.5	14.98	15.5	68.0	4		Materialization against the ACQ is more than trigger level
	89 YERMARUS TPP	0.62	13.6	13.09	13.6	47.0	3		Materialization against the ACQ is more than trigger level
Tamil Nadu									
	90 METTUR TPS	0.81	9.1	8.98	9.1	18.1	2		Materialization against the ACQ is more than trigger level
	91 METTUR TPS - II	0.78	7.9	6.16	7.9	14.2	2		Materialization against the ACQ is more than trigger level
	92 NORTH CHENNAI TPS	0.82	33.2	19.78	33.2	57.8	2		Materialization against the ACQ is more than trigger level
	93 TUTICORIN TPS	0.96	8.2	13.31	13.3	59.0	4		Materialization against the ACQ is more than trigger level
	94 VALLUR TPP	0.72	25.0	14.26	25.0	130.8	5		
Telangana									
	95 BHADRADRI TPP	0.69	13.0	9.83	13.0	70.7	5		
	96 KAKATIYA TPS	0.57	14.2	8.33	14.2	133.5	9		
	97 KOTHAGUDEM TPS (NEW)	0.64	14.6	8.46	14.6	98.0	7		
	98 KOTHAGUDEM TPS (STAGE-7)	0.50	7.4	5.23	7.4	52.6	7		
	99 RAMAGUNDEM STPS	0.62	32.4	21.33	32.4	192.8	6		
	100 RAMAGUNDEM-B TPS	0.77	0.3	0.64	0.6	14.4	23		
	101 SINGARENI TPP	0.58	16.5	9.12	16.5	123.6	7		
Total of Southern Region								0	
Eastern									
Bihar									
	102 BARAUNI TPS	0.63	5.1	5.90	5.9	114.2	19		
	103 BARH I	0.67	9.5	5.84	9.5	109.6	12		
	104 BARH II	0.67	19.0	11.67	19.0	219.3	12		
	105 KAHALGAON TPS	0.80	37.2	24.62	37.2	198.7	5		Materialization against the ACQ is more than trigger level
	106 MUZAFFARPUR TPS	0.77	4.6	3.95	4.6	83.7	18		Materialization against the ACQ is more than trigger level
	107 NABINAGAR STPP	0.58	19.0	10.14	19.0	240.4	13		
	108 NABINAGAR TPP	0.69	15.1	9.06	15.1	71.4	5		
Jharkhand									
	109 BOKARO TPS 'A' EXP	0.57	5.9	3.78	5.9	217.6	37		
	110 CHANDRAPURA(DVC) TPS	0.61	7.7	4.06	7.7	143.7	19		
	111 JOJBERA TPS	0.69	3.2	2.18	3.2	57.9	18		
	112 KODARMA TPP	0.62	12.0	8.23	12.0	156.0	13		
	113 MAHADEV PRASAD STPP	0.70	5.0	5.01	5.0	30.6	6		Materialization against the ACQ is more than trigger level
	114 MAITHON RB TPP	0.64	14.7	8.89	14.7	236.2	16		
	115 TENUGHAT TPS	0.75	5.3	4.16	5.3	41.3	8		Materialization against the ACQ is more than trigger level
Odisha									
	116 DARLIPALI STPS	0.71	26.6	14.95	26.6	352.7	13		
	117 DERANG TPP	0.70	15.7	11.10	15.7	1188.2	76		
	118 IB VALLEY TPS	0.83	18.4	19.16	19.2	327.3	17		
	119 KAMALANGA TPS	0.72	15.5	10.02	15.5	33.1	2		Materialization against the ACQ is more than trigger level

COAL INDIA LIMITED									
MARKETING & SALES DIVISION									
COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT									
Region/State	Name of Thermal Power Station	Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Coal Stock (In '000 Tonnes')	In Days	Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock
A	B	C	D	E	F	G	H=(G/F)		
120	VEDANTA TPP	0.76	4.4	6.02	6.0	86.4	14		Materialization against the ACQ is more than trigger level
121	TALCHER STPS	0.79	45.6	31.43	45.6	780.2	17		
West Bengal									
122	BAKRESWAR TPS	0.62	14.6	8.61	14.6	26.8	2		Materialization against the ACQ is more than trigger level
123	BANDEL TPS	0.78	3.9	2.77	3.9	1.1	0		Non payment of dues
124	BUDGE BUDGE TPS	0.58	10.6	5.77	10.6	231.7	22		
125	D.P.L. TPS	0.68	3.9	4.90	4.9	3.3	1		Non payment of dues
126	DURGAPUR STEEL TPS	0.69	12.7	9.16	12.7	132.8	10		
127	DURGAPUR TPS	1.06	3.4	2.93	3.4	28.5	8		Materialization against the ACQ is more than trigger level
128	FARAKKA STPS	0.70	20.4	19.34	20.4	96.4	5		Materialization against the ACQ is more than trigger level
129	HALDIA TPP	0.67	9.8	5.29	9.8	55.1	6		
130	HIRANMAYE TPP	0.72	4.3	2.83	4.3	43.8	10		Materialization against the ACQ is more than trigger level
131	KOLAGHAT TPS	0.75	6.8	8.33	8.3	0.4	0		Non payment of dues
132	MEJIA TPS	0.68	32.7	21.12	32.7	248.4	8		
133	RAGHUNATHPUR TPP	0.64	5.9	10.16	10.2	314.9	31		
134	SAGARDIGHI TPS	0.61	20.4	12.93	20.4	50.4	2		Non payment of dues
135	SANTALDIH TPS	0.70	8.5	4.64	8.5	5.7	1		
136	SOUTHERN REPL. TPS	0.75	1.8	1.34	1.8	51.5	28		
Total of Eastern Region									
North Eastern									
Assam									
137	BONGAIGAON TPP	0.58	9.3	5.79	9.3	50.6	5		Materialization against the ACQ is more than trigger level
Total of North Eastern Region									
Total Coal Stock		0.69	2055.2	1509.8	2113.4	20064.1	9	0	

Note

- https://cea.nic.in/wp-content/uploads/2020/04/guidelines_dcr.pdf
- % Materialization against ACQ is taken from 01.04.21 to 28.02.2022
- Plant wise Specific Coal Consumption = (Coal Requirement @85% PLF*1000)/(Capacity*24*0.85)- Source:- Daily coal stock report, CEA
- List of Linked Plants with CIL taken from the Daily Coal Report of CEA showing status as on 13.12.2021